

**234.260 When separate delivery equipment required for Class A and Class B liquids.**

No manifold, pump, meter, or hose shall be used for the delivery of Class A and Class B liquids on the same trip. Flushing, as provided in KRS 234.240, shall not be done during the course of deliveries. If the use of a manifold, pump, meter, or hose is required for the delivery of Class A and Class B liquids on the same trip, then separate delivery equipment shall be provided. Such equipment shall be tagged or painted to clearly indicate the class of liquid for which it is used.

**Effective:** June 17, 1954

**History:** Created 1954 Ky. Acts ch. 208, sec. 7, effective June 17, 1954.