

322.560 Maximum voltage exception for licensed electrical engineer.

Notwithstanding Article 555.4 of the National Electrical Code or any other provision of law, the maximum voltage of one thousand (1,000) volts for yard and pier distribution systems may be exceeded when engineered by an electrical engineer licensed under this chapter.

Effective: July 14, 2022

History: Created 2022 Ky. Acts ch. 69, sec. 2, effective July 14, 2022.